



Note 1: Compatible clamping rings: Watts B2-FLG, Zurn 56588, Zurn 29480, Wade W-3000-I-FRG, JR Smith 3260 and JR Smith 35400.

Note 2: Duro-Last membrane must extend beyond the inside of the clamping ring. The hole in the membrane must be larger than the drain pipe diameter.

Note 3: The designer should consider insulating the drain components below the deck to prevent potential condensation.

Note 4: Refer to specifications for vapor barrier, insulation and cover board requirements.

Note 5: Installation of drain bowl assembly to be completed by project general contractor and/or plumber.

|           |            |  |
|-----------|------------|--|
| REVISED:  | N/A        | DRAINAGE DETAIL FOR MECHANICALLY FASTENED SYSTEMS    |
| PREVIOUS: | 01/26/2021 | CLAMPING RING ROOF DRAIN WITH DURO-LAST® DRAIN GUARD |
| SCALE:    | NONE       | NEW CONSTRUCTION OR RE-ROOF                          |