



- Note 1: Deck membrane must be fastened around perimeter of roof penetration as per respective zone the skylight is located within (field, perimeter, corner).
- Note 2: All field welds must be a minimum of 1-1/2 in. (40 mm) wide.
- Note 3: Refer to specifications for vapor barrier, insulation, and cover board requirements.

REVISED: N/A	TPO ROOF PENETRATION DETAIL FOR ADHERED NON FLEECE SYSTEMS
PREVIOUS: 05/06/2026	SKYLIGHT CURB MOUNT PENETRATION
SCALE: NONE	NEW CONSTRUCTION OR RE-ROOF