



- Note 1: Deck membrane shall be fastened around the perimeter of the roof access hatch as per the respective zone the roof access hatch is located within (field, perimeter, corner).
- Note 2: Flashing membrane must loop over the foam backer rod. Foam backer rod shall be of sufficient size to compress when installed.
- Note 3: All field welds shall be a minimum of 1-1/2 inches wide.
- Note 4: Refer to specifications for vapor barrier, insulation and cover board requirements.

REVISED:	N/A	ROOF PENETRATION DETAIL FOR ADHERED NON-FLEECE SYSTEMS
PREVIOUS:	11/02/2023	ROOF ACCESS HATCH - OPTION 1
SCALE:	NONE	NEW CONSTRUCTION OR RE-ROOF