



- Note 1: Cut Termination Bar slightly larger than side of angle iron to allow for compression of Termination Bar by Panduit bands.
- Note 2: It is required to use 2 Panduit stainless steel bands.
- Note 3: Circumference of round Stack Flashing should be equal to or greater than all sides of angle iron.
- Note 4: Round flashings cannot be field-fabricated.
- Note 5: All field welds must be a minimum of 1-1/2 in. (40 mm) wide.
- Note 6: Refer to specifications for vapor barrier, insulation, and cover board requirements.

REVISED:	N/A	TPO ROOF PENETRATION DETAIL FOR ADHERED NON FLEECE SYSTEMS
PREVIOUS:	05/07/2026	ANGLE IRON FLASHING
SCALE:	NONE	NEW CONSTRUCTION OR RE-ROOF