



- Note 1: Membrane must be fastened around the perimeter of the drain as per respective zone the drain is located within (field, perimeter, corner). No less than one fastener per drain.
- Note 2: The openings in the composite drain rings (CDR) must face in opposite directions. Sealant and CDRs are to match locations.
- Note 3: The top of the CDRs must be a minimum of 2 inches from the top of the overflow drain.
- Note 4: All field welds shall be a minimum of 1-1/2 inches wide.
- Note 5: Refer to specifications for vapor barrier, insulation and cover board requirements.

REVISED: 10/17/22

DRAINAGE DETAIL FOR ADHERED NON-FLEECE SYSTEMS

PREVIOUS: N/A

OVERFLOW DRAIN

SCALE: NONE

NEW CONSTRUCTION OR RE-ROOF