

ADHERED 15 and 20-YEAR WARRANTY REQUIREMENTS

The following warranty requirements are in addition to the requirements set forth within each adhered Duro-Last® Roofing System Specification, such as, but not limited to, the peel stop requirements of Detail Drawing AS9060.

	15-Year NDL	20-Year NDL
Minimum Mil Thickness	40 mil nominal	50 mil nominal
Approved Membranes		
Duro-Last® (DL)	Refer to Approved Decks and Approved Adhesives	Refer to Approved Decks and Approved Adhesives
Duro-Last X™ (DLX)		
Duro-Tuff® (DT)		
Duro-Fleece® (DF)		
Duro-Fleece Plus® (DFP)		
Duro-Last EV (DL EV)		
Duro-Last EV Fleece (EVF)		
Parapets	Minimum of 40 mil nominal	Minimum of 50 mil nominal
Flashings	Minimum of 40 mil nominal	
T-Lap Patches	Minimum of 40 mil nominal	
Other Criteria		
Installing Contractor Level	All Duro-Last contractors (Reference pricing schedule for standard, Master, Elite and Platinum contractor levels under Sales/Price Lists on the Duro-Last Portal)	
Peel Stop	Refer to Detail Drawing AS9060	
Cover Board ¹	Not required unless specified within Detail Drawing AS9060	
Insulation	When required by the local code authority, or specified within Detail Drawing AS9060 ²	
Vapor Barrier	When required by a design professional (Confirm compatibility with Approved Adhesives)	
Edge Details	Non-fleece membranes: AS3000 -series details required Fleece membranes: DF3000 -series details required	
Consequential Damages	Available depending upon membrane type and warranty selection	
Transfer of Warranty	No inspection or fee	Inspection and fee (Refer to Pricing)
New Construction or Full Tear Off	Appropriate specification requirements must be met	
Recover	Appropriate specification requirements must be met	
Pricing		
Base Warranty Charges and Fees	Refer to the Duro-Last Price List under Sales/Price Lists on the Duro-Last Portal	

¹ Approved Duro-Guard® cover boards:
DensDeck Prime, Securock Gypsum-Fiber, DEXcell FA Glass Mat and DEXcell Cement

² If any insulation is required by the local code authority, insulation shall be installed in not less than two layers, and the edge joints between each layer shall be staggered a minimum of six inches. Two layers of insulation are not required where insulation tapers to the roof deck at a gutter edge, roof drain or scupper.

Requirements continued on page 2.

Requirements continued from page 1.

		15-Year NDL	20-Year NDL	
Approved Decks				
(Peel stop requirements of Detail Drawing AS9060 must be met, if applicable)				
	Any mechanically fastened insulation and/or cover board	All adhered insulation and/or cover board layers	Any mechanically fastened insulation and/or cover board	All adhered insulation and/or cover board layers
Wood (5/8-inch Plywood or 1-inch Plank minimum)	Pull value of 250 lbs, or greater	Adhesion value of 150 lbs, or greater, per square foot (1'x1' tester = 150 lbs minimum, 2'x2' tester = 600 lbs minimum)	Pull value of 250 lbs, or greater	Adhesion value of 150 lbs, or greater, per square foot (1'x1' tester = 150 lbs minimum, 2'x2' tester = 600 lbs minimum)
Steel				
Concrete (steel plates only)	No		No	
Lightweight Insulating Concrete				
Gypsum				
Cementitious Wood Fiber				
Metal Standing Seam	Pull value of 250 lbs, or greater. Base layer must be mechanically fastened. Subsequent layers may be adhered.			
Approved Adhesives				
Adhesive	Membrane	Insulation/Cover Board		
SB IV Adhesive	Yes, non-fleece membranes only	No		
Solvent-Grip® Plus	Yes, non-fleece membranes only	No		
WB II Adhesive	Yes, all membranes (Must not be applied to any roofing assembly that includes vapor barrier products)	No		
TRUFAST® Roofing Adhesive	Yes, fleece membranes only – splatter	Yes – ribbons		
Duro-Grip® CR-20	Yes, fleece membranes only – splatter	Yes – ribbons		
Duro-Grip Millennium Weather-Tite® Hurricane Force® PG-1	No	Yes – ribbons		
Duro-Grip Millennium Weather-Tite® One Step™	No	Yes – ribbons		
Duro-Grip OlyBond500® (Canister)	Yes, fleece membranes only – splatter	Yes – ribbons		
Duro-Grip OlyBond500® (Bag-in-Box)	No	Yes – ribbons		
Duro-Grip INSTA STIK™	No	Yes – ribbons		