



Note 1: Finished detail must not impede the drainage or flow of water.

Note 2: Tie-in detail for all flat surfaces. The use of Detail Drawing AS1070 will be required in conjunction with Detail Drawing AS1090 when tie-in is across metal flutes.

Note 3: Wood nailers must withstand a minimum force of 180 pounds per lineal foot (per building code). Any pull values greater than 270 pounds will allow for a fastener spacing of 18 inches on center. Pull values less than 270 pounds will require additional fasteners. **The installing contractor is responsible for meeting building codes.**

Note 4: Refer to specifications for vapor barrier, insulation and cover board requirements.

Note 5: All field welds shall be a minimum of 1-1/2 inches wide.

REVISED:	N/A	GENERAL DETAIL FOR ADHERED NON-FLEECE SYSTEMS
PREVIOUS:	09/12/2023	SINGLE-PLY ROOF TIE-IN
SCALE:	NONE	RE-ROOF