



- Note 1: This detail cannot be used on drains larger than 2 inches in diameter.
- Note 2: The membrane shall be terminated through the drain pipe flange and directly to the deck as shown above. The membrane cannot be terminated through insulation, existing roofs or recover boards.
- Note 3: All field welds shall be a minimum of 1-1/2 inches wide.
- Note 4: Refer to specifications for vapor barrier, insulation and cover board requirements.

REVISED:	N/A	DRAINAGE DETAIL FOR ADHERED NON-FLEECE SYSTEMS
PREVIOUS:	12/16/2022	2-INCH DRAIN ADAPTER
SCALE:	NONE	NEW CONSTRUCTION OR RE-ROOF