



Note 1: Precaution must be taken to ensure that all wall-to-deck transitions are sealed.

Note 2: Metal flange is back-sealed with factory-applied sealant. Remove paper backing when ready to install scupper.

Note 3: All field welds must be a minimum of 1-1/2 inches wide.

Note 4: Refer to specifications for vapor barrier, insulation, and cover board requirements.

Note 5: Termination Bar, approved Duro-Last sealant and approved Duro-Last fasteners spaced 6 inches on center around entire opening of scupper.

REVISED:	N/A	DRAINAGE DETAIL FOR ADHERED NON-FLEECE SYSTEMS
PREVIOUS:	02/14/2023	SINGLE SKIRTED VINYL-COATED METAL SCUPPER WITH FLANGE
SCALE:	NONE	NEW CONSTRUCTION OR RE-ROOF