



- Note 1: Precaution must be taken to ensure that all wall-to-deck transitions are sealed.
- Note 2: All field welds shall be a minimum of 1-1/2 inches wide.
- Note 3: Refer to specifications for vapor barrier, insulation and cover board requirements.

REVISED: N/A	DRAINAGE DETAIL FOR ADHERED NON-FLEECE SYSTEMS
PREVIOUS: 11/02/2022	SINGLE SKIRTED VINYL-COATED METAL SCUPPER
SCALE: NONE	NEW CONSTRUCTION OR RE-ROOF