



Note 1: This detail may also be used on parapet walls.

Note 2: All adhered installations that utilize Vinyl-Coated Metal Drip Edge require a continuous cleat. Continuous cleat must be fastened 6 in. (152 mm) on center. Use roofing nails that penetrate substrate by a minimum of 1-1/2 in. (40 mm).

Note 3: Each section must overlap by 1-1/2 in. (40 mm).

Note 4: All field welds must be a minimum of 1-1/2 in. (40 mm) wide.

Note 5: Refer to General Requirements for wood nailer requirements.

Note 6: Refer to specifications for vapor barrier, insulation, and cover board requirements.

REVISED: N/A	TPO EDGE DETAIL FOR ADHERED NON FLEECE SYSTEMS
PREVIOUS: 09/26/2025	2" - 8" VINYL-COATED METAL DRIP EDGE
SCALE: NONE	NEW CONSTRUCTION OR RE-ROOF