
DURO-LAST® THE WORLD'S BEST ROOF®

DETAIL TAS3556



Note 1: A 1/8 in. (3 mm) gap is required between sections of cleat.

Note 2: Each section of cover must overlap 1-1/2 in. (38 mm).

Note 3: Each section of hook strip must overlap 1-1/2 in. (38 mm).

Note 4: Stagger all seams by a minimum of 12 in. (305 mm) between cleat, hook strip, and cover.

Note 5: This detail may also be used on parapet walls.

Note 6: Use roofing nails that penetrate substrate by a minimum of 1-1/2 in. (38 mm).

Note 7: All field welds must be a minimum of 1-1/2 in. (40 mm) wide.

Note 8: Refer to General Requirements for wood nailer requirements.

Note 9: Refer to specifications for vapor barrier, insulation, cover board, and deck requirements.

REVISED:	08/07/2026	TPO METAL EDGE DETAIL FOR ADHERED NON-FLEECE SYSTEMS
CREATED:	09/26/2025	T-EDGE ADVANCED
SCALE:	NONE	NEW CONSTRUCTION OR RE-ROOF