



Note 1: This detail may also be used on parapets.

Note 2: This detail is NOT FOR USE where drainage runs off the building.

Note 3: Allow for 1/8 in. (3 mm) expansion gap between 10 ft (3 m) lengths of snap-on base. Overlap snap-on covers by 2 in. (51 mm) between 10 ft (3 m) lengths.

Note 4: All field welds must be a minimum of 1-1/2 in. (40 mm) wide.

Note 5: Refer to General Requirements for wood nailer requirements.

Note 6: Refer to specifications for vapor barrier, insulation, and cover board requirements.

REVISED: 00/00/0000

TPO EDGE DETAIL FOR MECHANICALLY FASTENED SYSTEMS

PREVIOUS: 10/17/2025

UNIVERSAL 2-PIECE COMPRESSION EDGE LG (MEMBRANE GREATER THAN 45 MILS)

SCALE: NONE

NEW CONSTRUCTION OR RE-ROOF