

**Nemo|etc.**353 Christian Street, Unit #13  
Oxford, CT 06478  
(203) 262-9245

ENGINEER

EVALUATE

TEST

CONSULT

**ROOF SYSTEM ASSESSMENT REPORT  
DYNAMIC UPLIFT RESISTANCE PER CSA A123.21**

CLIENT:	DURO-LAST, INC.	TEST DATE:	2017-07-14
DOCUMENT NO.	DL-MARS-7	PUBLICATION DATE:	2022-07-12
TEST PANEL NO.	DRL-D1D	REVISION NO.	1
SYSTEM TYPE:	D-1	REEVALUATION DATE:	2025-07-12

**MECHANICALLY ATTACHED ROOFING SYSTEM (MARS) SUMMARY**

PERFORMANCE⇒	PASSING PRESSURE	WIND UPLIFT RESISTANCE (with SF of 1.5)
	128 psf (6.1 kPa)	85 psf (4.1 kPa)

COMPONENT	ALLOWABLE PRODUCTS	BY
MEMBRANE⇒	Duro-Last, min. nominal 40-mil	Duro-Last, Inc.
ATTACHMENT:	Mechanically attached, 12-inch o.c. within 3-inch wide fastening tabs spaced 60-inch o.c.	
	Duro-Last Concrete Screws with Duro-Last Poly-Plates or Duro-Last Cleat-Plates	Duro-Last, Inc.
INSULATION, TOP LAYER⇒	Min. 1.5-inch thick DURO-GUARD ISO II-A, DURO-GUARD ISO II-G, DURO-GUARD ISO II-H, DURO-GUARD ISO III-A or DURO-GUARD ISO III-H	Duro-Last, Inc.
ATTACHMENT:	Mechanically attached; 1 per 5.3 ft <sup>2</sup> ; 6 parts per 4x8 ft board	
	Duro-Last #14 Heavy Duty with Duro-Last 3-inch Metal Plates	Duro-Last, Inc.
INSULATION, BASE LAYER⇒	(Optional) One or more layers DURO-GUARD ISO II-A, DURO-GUARD ISO II-G, DURO-GUARD ISO II-H, DURO-GUARD ISO III-A or DURO-GUARD ISO III-H, any thickness	Duro-Last, Inc.
ATTACHMENT:	Loose-laid	
VAPOUR BARRIER⇒	(Optional) Duro-Blue or Duro-Last Vapor Barrier	Duro-Last, Inc.
ATTACHMENT:	Duro-Blue: Loose-laid with taped joints	
	Duro-Last Vapor Barrier: self-adhering	
DECK⇒	Minimum 2,500 psi structural concrete	Various
FASTENER POINT-LOAD⇒	Insulation Fasteners: 678 lbf (3015 N)	
	Membrane Fasteners: 640 lbf (2846 N)	

**ROOF SYSTEM ASSESSMENT REPORT, DYNAMIC UPLIFT RESISTANCE PER CSA A123.21**

CLIENT:	DURO-LAST, INC.	PUBLICATION DATE:	2022-07-12
DOCUMENT NO.	DL-MARS-7	REVISION NO.	1
TEST PANEL NO.	DRL-D1D	RE-EVALUATION DATE:	2025-07-12

Page 2 of 2

**NEMO|etc.****NEMO ETC CREDENTIALS**

TYPE	ENTITY	REFERENCE
ISO/IEC 17025 Accreditation	International Accreditation Service (IAS)	<a href="#">TL-689</a>
TAS 301 Certification	Miami-Dade	<a href="#">21-0409.01</a>
Third Party Test Data Program	UL, LLC	<a href="#">DA2862</a>
Test Lab Listing	Roofing Contractors Association of British Columbia	<a href="#">www.rcabc.org</a>

**REPORT HISTORY**

DATE	EVENT	NOTES	AUTHORIZED BY:
2021-01-11	FINAL	None	RN
2022-07-12	RE-EVALUATION 1	None	RN

This report and the data contained therein is the sole property of NEMO|etc. and the named client. This report shall not be reproduced outside NEMO|etc. except by the named client without written permission by the named client, in which case the report shall be reproduced in its entirety.

**END OF REPORT**