



Note 1: All field welds shall be a minimum of 1-1/2 inches wide.

Note 2: Non-fleece membranes must be the same, or greater, mil thickness as the Duro-Fleece membranes.

Note 3: Refer to specifications for vapor barrier, insulation and cover board requirements.

REVISED: N/A	GENERAL DETAIL FOR ADHERED DURO-FLEECE <sup>®</sup> SYSTEMS
PREVIOUS: 01/15/2024	END LAPS
SCALE: NONE	NEW CONSTRUCTION OR RE-ROOF