



Note 1: Deck membrane shall be fastened around the perimeter of the roof access hatch as per the respective zone the roof access hatch is located within (field, perimeter, corner).

Note 2: All field welds shall be a minimum of 1-1/2 inches wide.

Note 3: Refer to specifications for vapor barrier, insulation and cover board requirements.

REVISED:	N/A	ROOF PENETRATION DETAIL FOR ADHERED NON-FLEECE SYSTEMS
PREVIOUS:	11/03/2023	ROOF ACCESS HATCH - OPTION 2
SCALE:	NONE	NEW CONSTRUCTION OR RE-ROOF