



Note 1: All field welds must be a minimum of 1-1/2 in. (40 mm) wide.

Note 2: Refer to specifications for vapor barrier, insulation, and cover board requirements.

REVISED: N/A	TPO GENERAL DETAIL FOR ADHERED NON-FLEECE SYSTEMS
PREVIOUS: 11/07/2025	ADHERED TO MECHANICALLY FASTENED TIE-IN
SCALE: NONE	NEW CONSTRUCTION OR RE-ROOF