



TIE-INS TO EXISTING ROOFING SYSTEMS NOT WARRANTED BY DURO-LAST.

Note 1: Tie-in detail for all flat surfaces. The use of Detail T1070 will be required in conjunction with Detail T1080 when tie-in is across metal flutes.

Note 2: All field welds must be a minimum of 1-1/2 in. (40 mm) wide.

Note 3: Three-course the lap joint with fabric and One-Part Pourable Sealer. Fabric must overlap the membrane by 3 in. (76 mm) minimum. One-Part Pourable Sealer must extend past the fabric by 1/4 in. (6 mm) minimum.

REVISED: 00/00/0000	TPO GENERAL DETAIL FOR MECHANICALLY FASTENED SYSTEMS
PREVIOUS: 04/30/2026	ASPHALT ROOF TIE-IN
SCALE: NONE	RE-ROOF