



Note 1: This detail cannot be used on drains larger than 2 inches in diameter.

Note 2: The membrane cannot be terminated through insulation, existing roofs or recover boards.

Note 3: All field welds shall be a minimum of 1-1/2 inches wide.

Note 4: Refer to specifications for vapor barrier, insulation and cover board requirements.

REVISED:	N/A	DRAINAGE DETAIL FOR ADHERED FLEECE SYSTEMS
PREVIOUS:	01/19/2023	2-INCH DRAIN ADAPTER
SCALE:	NONE	NEW CONSTRUCTION OR RE-ROOF