



Note 1: Precaution must be taken to ensure that all wall-to-deck transitions are sealed.

Note 2: All field welds shall be a minimum of 1-1/2 inches wide.

Note 3: Refer to specifications for vapor barrier, insulation and cover board requirements.

Note 4: Nailers and approved Duro-Last sealant to be level with opening and extend 2 inches past each side of opening. Fasten with approved Duro-last fasteners spaced 12 inches on center (minimum of 3).

REVISED:	N/A	DRAINAGE DETAIL FOR ADHERED FLEECE SYSTEMS
PREVIOUS:	01/16/2023	SINGLE SKIRTED VINYL-COATED METAL SCUPPER
SCALE:	NONE	NEW CONSTRUCTION OR RE-ROOF