



Note 1: 1 1/4-inch roofing nails spaced 6 inches on center.

Note 2: Deck membrane shall be fastened around perimeter of roof penetration as per respective zone the penetration is located within (field, perimeter, corner).

Note 3: All field welds shall be a minimum of 1-1/2 inches wide.

Note 4: Refer to specifications for vapor barrier, insulation and cover board requirements.

REVISED: N/A	ROOF PENETRATION DETAIL FOR ADHERED NON-FLEECE SYSTEMS
PREVIOUS: 07/14/2023	RECTANGULAR PENETRATION
SCALE: NONE	NEW CONSTRUCTION OR RE-ROOF