



- Note 1: 1-inch #10 wood screw (by others) fastened through predrilled holes in skylight frame. (Allow 3/8 inch min. overhang clearance of skylight frame on each side.)
- Note 2: Skylight components including flanges, installed as per skylight manufacturer's specifications.
- Note 3: Deck membrane shall be fastened around perimeter of roof penetration as per respective zone the penetration is located within (field, perimeter, corner).
- Note 4: All field welds shall be a minimum of 1-1/2 inches wide.
- Note 5: Refer to specifications for vapor barrier, insulation and cover board requirements.

REVISED:	N/A	ROOF PENETRATION DETAIL FOR ADHERED NON-FLEECE SYSTEMS
PREVIOUS:	07/13/2023	SKYLIGHT CURB MOUNT PENETRATION
SCALE:	NONE	NEW CONSTRUCTION OR RE-ROOF