



Note 1: All coping cap joints must utilize a 6-inch concealed splice plate.

Note 2: Refer to Detail Drawing 6053 for splice plate installation instructions.

Note 3: All fasteners must penetrate into nailer by a minimum of 1-1/2 inches.

Note 4: Fasten other manufacturers' products per manufacturer's specifications.

Note 5: Wood nailers must withstand a minimum force of 180 pounds per lineal foot (per building code). Any pull values greater than 270 pounds will allow for a fastener spacing of 18 inches on center. Pull values less than 270 pounds will require additional fasteners. **The installing contractor is responsible for meeting building codes.**

Note 6: Fasten Exceptional® Metals coping cap with hex head screws and neoprene washers at 24 inches on center, max. (Notes 3, 4).

REVISED:	N/A	PARAPET WALL DETAIL FOR ADHERED NON-FLEECE SYSTEMS
PREVIOUS:	02/20/2024	CANTED COPING WITH CONTINUOUS CLEAT
SCALE:	NONE	NEW CONSTRUCTION OR RE-ROOF