
DETAIL 4022



Note 1: Deck membrane shall be fastened around perimeter of roof penetration as per respective zone the rectangular penetration is located within (field, perimeter, corner). Membrane may be turned up and fastened into the curb. Refer to Details RG6000 and RG6001.

Note 2: Metal flashing 24 ga. min. must have an approved fastener within 1 in. (25 mm) of each corner.

Note 3: All field welds must be a minimum of 1-1/2 in. (40 mm) wide.

Note 4: Refer to specifications for vapor barrier, insulation, cover board, and deck requirements.

REVISED:	N/A	ROOF PENETRATION DETAIL FOR MECHANICALLY FASTENED SYSTEMS
CREATED:	10/15/2026	RECTANGULAR PENETRATION - OPTION 3
SCALE:	NONE	EXISTING METAL COUNTERFLASHING