



Note 1: 1-3/4 or 4-inch Fascia Bar and Cover (cover optional) may be used in place of Termination Bar.

Note 2: Refer to Detail Drawings AS6010 and AS6011 for membrane fastening.

Note 3: All field welds shall be a minimum of 1-1/2 inches wide.

Note 4: Refer to specifications for vapor barrier, insulation and cover board requirements.

REVISED: N/A	PARAPET WALL DETAIL FOR ADHERED NON-FLEECE SYSTEMS
PREVIOUS: 07/17/2023	INSIDE WALL TERMINATION
SCALE: NONE	NEW CONSTRUCTION OR RE-ROOF