



Note 1: Tie-in detail for all flat surfaces. The use of Detail Drawing AS1070 will be required in conjunction with Detail AS1080 when tie-in is across metal flutes.

Note 2: All field welds shall be a minimum of 1-1/2 inches wide.

Note 3: Refer to specifications for vapor barrier, insulation and cover board requirements.

Note 4: New roofing material per asphalt manufacturer's requirements.

REVISED:	N/A	GENERAL DETAIL FOR ADHERED NON-FLEECE SYSTEMS
PREVIOUS:	12/08/2023	ASPHALT ROOF TIE-IN
SCALE:	NONE	RE-ROOF